


# Hygiene-Institut des Ruhrgebiets

Institut für Umwelthygiene und Toxikologie

Direktor: Prof. Dr. rer. nat. L. Dunemann

Träger: Verein zur Bekämpfung der Volkskrankheiten im Ruhrkohlengebiet e.V.



HYGIENE-INSTITUT · Postfach 10 12 55 · 45812 Gelsenkirchen / GERMANY

NEOTEX S.A.  
V. Moira Str.  
Industrial Area Mandra  
19600 MANDRA  
GREECE

Visitors-/Parcel Address:  
Rotthauer Str. 21  
45879 Gelsenkirchen

Telephone +49 (0) 209 9242-0  
Extension +49 (0) 209 9242-277  
Telefax +49 (0) 209 9242-212  
E-Mail r.weiss@hyg.de  
Internet www.hyg.de

Reference-No.: K-242315-14-WR/st  
Contact person: Roland Weiß (Dipl.-Biol.)  
Prolongation: K-173724-09-Ko/st

Gelsenkirchen, 11.04.2014

## TEST CERTIFICATE according to the DVGW Code of Practice W 347 "hygienic requirements for cement-bound materials for drinking water supply"

Product: Revinex Flex 2006

Specimen: prisms (grey)

### Test result:

The test specimen meets the requirements of the DVGW Code of Practice W 347 according to the test report **Ref.-No: K-173723-09-Ko/st dated 24.02.2009** for the following scopes:

Scope	Products / Components	Assessment
I	mortar lining of cast iron pipes and steel pipes	---
II	concrete pipes $\geq$ DN 300, reservoirs, cementitious coatings of reservoirs	passed
III	cement for tiles, joint filler, coating of fittings (e.g. for welding joints)	passed
IV	concrete components in protective areas of drinking water plants I, II, III	passed

This test certificate is valid beginning with the date of issue and is ending by **05.02.2019** as far as there are no changes in the formula.

The Director of the Hygiene-Institute  
on behalf of

Dr. rer. nat. Andreas Koch  
Head of the Dept. for water  
hygienic material testing



The assessment was based on the assumption that the used starting substances and monomers used to manufacture the product may completely known and no other substances are present in the product. The validity of this document expires in case of modifications in the composition of the product or the processing conditions. The results and evaluations refer to the groups of test items. This document may not be published without our written permission only complete and unchanged or duplicated.



Träger: Verein zur Bekämpfung der Volkskrankheiten im Ruhrkohlengebiet e.V., Vereinsregister: VR 519 Amtsgericht Gelsenkirchen, USt.-ID: DE125018356  
Vorstand: Prof. Dr. Werner Schlake (Vors.), Prof. Dr. Jürgen Kretschmann, Dr. Emanuel Grün, Volker Vohmann, Prof. Dr. Lothar Dunemann (geschäftsf. Vorstand)